



SLOPE MAY VARY FROM
 1/4" / FT (MIN) TO
 3:1 (MAX) EITHER UP OR
 DOWN FROM TOP OF CURB(TYP.)

6" PORTLAND CEMENT CONCRETE PAVEMENT
 (MIN. CEMENT CONTENT OF 5-1/2 SACKS PER
 C.Y., AND A MIN. COMPRESSIVE STRENGTH
 OF 3600 psi @ 28 DAYS)

NOTES:

1. TRANSVERSE SAWED CONTRACTION JOINTS AT 12' INTERVALS FOR CONCRETE PAVEMENT.
2. GEOTECHNICAL REPORT (LIME SERIES TEST) PREPARED BY LICENSED ENGINEER IS REQUIRED TO DETERMINE LIME OR CEMENT APPLICATION RATE.
3. MINIMUM LIME APPLICATION RATE SHALL BE 30 LBS./S.Y.
4. SUBGRADE COMPACTION SHALL BE 95% STANDARD PROCTOR DENSITY.

P-01	RESIDENTIAL STREET (L2U) CONCRETE
CITY OF BURLESON	
ORIGINAL	10/6/06
REVISION	SWC
REVISION	
REVISION	