



SLOPE MAY VARY FROM  
 1/4" / FT (MIN) TO  
 3:1 (MAX) EITHER UP OR  
 DOWN FROM TOP OF CURB (TYP.)

7" HOT MIX ASPHALTIC CONCRETE:  
 2" TYPE "D" H.M.A.C.  
 5" TYPE "A" OR TYPE "B" H.M.A.C. (2 LIFTS)

NOTES:

1. GEOTECHNICAL REPORT (LIME SERIES TEST) PREPARED BY LICENSED ENGINEER IS REQUIRED TO DETERMINE LIME OR CEMENT APPLICATION RATE.
2. MINIMUM LIME APPLICATION RATE SHALL BE 30 LBS./S.Y.
3. SUBGRADE COMPACTION SHALL BE 95% STANDARD PROCTOR DENSITY.
4. BAR DITCH SIDE SLOPE VARIES DEPENDING UPON DESIGN. NO GREATER THAN 3:1 WITHOUT ARMORING.
5. FOR 30" GUTTER DETAIL, SEE CURB & GUTTER DETAILS.

P-02	RESIDENTIAL STREET (L2U) HMAC
CITY OF BURLESON	
ORIGINAL	10/6/06
REVISION	SWC
REVISION	
REVISION	