



NOTES:

1. TRANSVERSE SAWED CONTRACTION JOINT AT 12' INTERVALS FOR CONCRETE PAVEMENT.
2. BAR DITCH SIDE SLOPE VARIES DEPENDING UPON DESIGN. NO GREATER THAN 3:1 WITHOUT AMORING.
3. GEOTECHNICAL REPORT (LIME SERIES TEST) PREPARED BY A LICENSED ENGINEER IS REQUIRED TO DETERMINE LIME OR CEMENT APPLICATION RATE.
4. MINIMUM LIME APPLICATION RATE SHALL BE 30 LBS./S.Y.
5. SUBGRADE COMPACTION SHALL BE 95% STANDARD PROCTOR DENSITY.

P-03	RURAL RESIDENTIAL
CITY OF BURLESON	
ORIGINAL	1076706
REVISION	SWC
REVISION	
REVISION	