



NOTES:

1. TRANSVERSE SAWED CONTRACTION JOINTS AT 12' INTERVALS FOR CONCRETE PAVEMENT. LONGITUDINAL SAWED CONTRACTION JOINTS AT 11' INTERVALS.
2. GEOTECHNICAL REPORT (LIME SERIES TEST) PREPARED BY LICENSED ENGINEER IS REQUIRED TO DETERMINE LIME OR CEMENT APPLICATION RATE.
3. MINIMUM LIME APPLICATION RATE SHALL BE 30 LBS./S.Y.
4. SUBGRADE COMPACTION SHALL BE 95% STANDARD PROCTOR DENSITY.

P-05	MINOR COLLECTOR (C3U) CONCRETE
CITY OF BURLESON	
ORIGINAL	10/6/06
REVISION	SWC
REVISION	
REVISION	