



NOTES:

1. TRANSVERSE SAWED CONTRACTION JOINTS AT 15' INTERVALS & LONGITUDINAL SAWED CONTRACTION JOINTS AT 11' INTERVALS FOR CONCRETE PAVEMENT.
2. GEOTECHNICAL REPORT (LIME SERIES TEST) PREPARED BY LICENSED ENGINEER IS REQUIRED TO DETERMINE LIME OR CEMENT APPLICATION RATE.
3. MINIMUM LIME APPLICATION RATE SHALL BE 30 LBS./S.Y.
4. SUBGRADE COMPACTION SHALL BE 95% STANDARD PROCTOR DENSITY.

P-07	MAJOR COLLECTOR (C4U)
CITY OF BURLESON	
ORIGINAL	10/6/06
REVISION	SWC
REVISION	
REVISION	