



NOTES:

1. TRANSVERSE SAWED CONTRACTION JOINTS AT 15' INTERVALS AND LONGITUDINAL SAWED CONTRACTION JOINTS 12' FROM OUTSIDE BACK OF CURBS.
2. GEOTECHNICAL REPORT (LIME SERIES TEST) PREPARED BY LICENSED ENGINEER IS REQUIRED TO DETERMINE LIME OR CEMENT APPLICATION RATE.
3. MINIMUM LIME APPLICATION RATE SHALL BE 30 LBS./S.Y.
4. SUBGRADE COMPACTION SHALL BE 95% STANDARD PROCTOR DENSITY.

P-09	MINOR ARTERIAL CONVENTIONAL (P4D)
CITY OF BURLESON	
ORIGINAL	10/6/06
REVISION	SWC
REVISION	
REVISION	