



NOTES

1. DROP PIPE SHALL BE ONE SIZE LARGER THAN SEWER INFLUENT PIPE.
2. ALL STANDARD MANHOLE DETAILS IN FIGURES S-03 AND/OR S-04 APPLY TO DROP MANHOLE CONSTRUCTION.
3. ALL DROP MANHOLES SHALL BE 72" DIAMETER.
4. NO DROP PIPING SHALL BE REQUIRED IF SEWER INFLUENT PIPE FLOWLINE IS 18" OR LESS ABOVE MAIN SEWER PIPE FLOWLINES OR IF MAIN SEWER PIPE BENCH IS HIGHER THAN SEWER INFLUENT FLOWLINE.

S-08	INTERNAL DROP MANHOLE NEW CONSTRUCTION	
CITY OF BURLESON		
ORIGINAL	10/6/06	SWC
REVISION		
REVISION		
REVISION		