



NOTES

1. WHERE TAPPING EXISTING MAINS OR PVC WATER MAINS, DOUBLE STAINLESS STEEL STRAP, EPOXY-COATED SADDLES SHALL BE USED.
2. COPPER SERVICES SHALL BE CONTINUOUS WITH NO JOINTS FROM CORP. STOP TO QUARTER BEND.
3. ALL COPPER FITTINGS SHALL BE COMPRESSION FITTINGS.
4. METERS SHALL NOT BE INSTALLED IN EXISTING OR PROPOSED SIDEWALK OR DRIVEWAYS.
5. METER BOX SHALL BE:
 ALLIANCE 1200.SBTR (NON-TRAFFIC)
 ROTEC DFW36C-SBSM (TRAFFIC)
6. ANGLE BALL METER VALVES SHALL BE INSTALLED AND SHALL MEET THE SPECIFICATIONS OF CATALOG NO. BA13-332W AS MANUFACTURED BY THE FORD METER BOX COMPANY OR EQUAL.
7. ANGLE STOPS SHALL BE FULL ROTATION WITH LOCK RINGS AND METER SPUD.

W-07	SINGLE WATER SERVICE (1" SERVICE FOR 1" & 3/4" OUTLETS)	
CITY OF BURLESON		
ORIGINAL	10/6/06	SWC
REVISION		
REVISION		
REVISION		