



NOTES

1. DOUBLE STRAPPED BRONZE, STAINLESS STEEL, OR EPOXY COATED DUCTILE IRON SADDLES SHALL BE USED TO TAP ALL MAINS.
2. COPPER SERVICES SHALL BE CONTINUOUS WITH NO INTERMEDIATE FITTINGS ALLOWED.
3. ALL COPPER FITTINGS SHALL BE COMPRESSION FITTINGS.
4. INSTALL 2" PIPE AND TAP FOR BOTH 1 1/2" AND 2" METER INSTALLATIONS.
5. DOUBLE WRAP BRONZE STRAPS WITH POLY WRAP.

W-08	2" WATER SERVICE/FLUSH POINT (2" SERVICE FOR 1 1/2" & 2" OUTLETS)	
CITY OF BURLESON		
ORIGINAL	10/6/06	SWC
REVISION		
REVISION		
REVISION		