



NOTES:

1. UNIT SHALL BE HYDRO-GUARD STANDARD INTEGRATED UNIT (HG1-INT) OR APPROVED EQUAL.
2. INSTALLATION SHALL BE IN ACCORDANCE WITH MANUFACTURERS RECOMMENDATIONS.
3. UNIT SHALL BE INSTALLED AT ALL DEADEND WATER MAINS.

W-11	AUTOMATIC WATER DISTRIBUTION FLUSHING SYSTEM	
CITY OF BURLESON		
ORIGINAL	10/6/06	SWC
REVISION		
REVISION		
REVISION		